

MONITORING REPORT

Version 04 dated 03.06.2011

“RECONSTRUCTION OF KRAMATORSK HEAT AND POWER PLANT”

Monitoring period: 01.01.2010 – 31.12.2010

CONTENTS

- A. General description of the project activity
 - A.1. Brief description of the project activity
 - A.2. Project participants
 - A.3. Location of the project activity
 - A.4. Technical description of the project
 - A.5. Title, reference and version of the baseline and monitoring methodology applied to the project activity
 - A.6. Registration date of the project activity
 - A.7. Crediting period of the project activity and related information
 - A.8. Name of responsible person(s)/entity(ies)

- B. Implementation of the project activity
 - B.1. Implementation status of the project activity
 - B.2. Revision of the monitoring plan
 - B.3. Request for deviation applied to this monitoring period
 - B.4. Notification or request of approval of changes

- C. Description of the monitoring system

- D. Data and parameters monitored
 - D.1. Data and parameters used to calculate baseline emissions
 - D.2. Data and parameters used to calculate project emissions
 - D.3. Data and parameters used to calculate leakage emissions
 - D.4. Other relevant data and parameters

- E. Emission reductions calculation
 - E.1. Baseline emissions calculation
 - E.2. Project emissions calculation
 - E.3. Leakage calculation
 - E.4. Emission reductions calculation
 - E.5. Comparison of actual emission reductions with estimates in the registered PDD
 - E.6. Remarks on difference from estimated value

Annex 1. Data as to the meters of measurement of power supplied to consumers

Annex 2. Detailed information as to the technical breakdowns during 2010

SECTION A. General description of the project activity

A.1. Brief description of the project activity:

Joint Implementation project “Reconstruction of Kramatorsk heat and power plant”

Sectoral scope:

1: Energy industries (renewable/non-renewable sources)

Monitoring period: 01.01.2010 – 31.12.2010 (including the first and the last day)

The main goal of Joint implementation project “Reconstruction of Kramatorsk heat and power plant” is implementation of measures which will improve fuel consumption efficiency and will reduce own consumption of electric power by the plant, therefore resulting in GHG emissions reduction to the atmosphere.

The project foresees large-scale reconstruction of existing equipment of Kramatorsk HPP. The program of reconstruction of Kramatorsk HPP within Joint implementation includes the following measures:

- Reconstruction of boilers № 7, 9;
- Reconstruction of turbines № 3, 4;
- Reconstruction of cooling tower № 1;
- Frequency controllers’ installation;
- Feeding pump replacement №5;
- Hydraulic ash removal modernization;

In addition to this, rehabilitation of district heating system in Kramatorsk is foreseen within JI project. It includes:

- Replacement of old heat pipelines which supply consumers with heat power generated at HPP by new pre-insulated pipes in polyurethane foam cover and pipes with lagging from mineral cotton;
- Replacement of 200 capacitive heat exchangers by plate heat exchangers at substations of the town;
- Major rehabilitation of boiler-rooms with replacement of pipes and valves.

As the result of reconstruction the efficiency of Kramatorsk HPP equipment will increase from 56% of gross efficiency (combined heat and electric capacity with the use of natural gas) to approximately 78% of efficiency with the use of natural gas and 65% of efficiency – with the use of coal. The increase of the equipment efficiency will lead to reduction of the level of fuel consumption. As far as natural gas is more expensive compared to coal, it is considered that fuel savings are to be completely savings of natural gas. This is conservative assumption. Besides, the reduction of own electric power consumption will allow increasing supply of electricity into the grid therefore contributing to additional emission reductions.

The project with the total investment costs over 67 million UAH will give the following benefits:

- Positive effect on the environment;
- Improvement of technical and economic indicators of work of HPP;
- Positive social effect.

Therefore, project implementation will be economically and socially beneficial.

Positive aspects of social and economic effect from the project implementation:

- The national grid of Ukraine and industrial consumers of Kramatorsk are expected to benefit from increased of reliability of power supply by the Kramatorsk HPP;
- Local community and employees of Kramatorsk HPP will benefit from the jobs available on long term prospective due to more reliable work of the enterprise in future;

- The industrial and residential consumers of Kramatorsk who will receive a better quality heat supply service.

Positive aspects of project effect on the environment of Kramatorsk:

-as a result of project implementation the amount of fossil fuel (valuable non-renewable source of energy) will be reduced at the process of heat and power energy generation;
 - project implementation will reduce greenhouse and toxic gases emissions (carbon dioxide, nitric oxide and carbon monoxide) and prevent further GHG accumulation at the atmosphere what in its turn causes climate change.

According to the data of Kramatorsk HPP as a result of implemented reconstruction of HPP and rehabilitation of heat supply network the following natural gas savings in 2010 occurred:

Natural gas savings from HPP reconstruction, ths. m ³	34 555
Natural gas saving from heat supply network rehabilitation, ths. m ³	387

A.2. Project Participants

The project participants and Parties involved are presented below in the Table 1 (according to the registered PDD version 2.2).

Table 1: Project participants

Party involved	Legal entity project participants (as applicable)	Please indicate if the Party involved wishes to be considered as project participant (Yes/No)
Ukraine (Host Party)	“Kramatorskteploenergo” LLC	No
Germany (Investor Party)	GreenStream Network GmbH	No

A.3. Location of the project activity:

The Project is located in town of Kramatorsk, Donetsk Region, the Eastern part of Ukraine

A.4. Technical description of the project

Currently there are three cogeneration turbines at Kramatorsk HPP: turbine № 2 of the type PTR-30-90/13 with installed capacity of 30 MW; turbines №3 and №4 of the type PTR-60-90/13 with installed capacity of 60 MW each.

Turbine №2 has been commissioned in 1955; turbines № 3 and № 4 – in 1973 and 1976 respectively. At the moment turbine № 2 has been mothballed and is not used for electric power generation.

There are 8 steam boilers at Kramatorsk HPP, 6 of which are under operation: 2 boilers of type TP-170 (boilers №4 and №5) as well as 4 boilers of the type BKZ-160-100 PT (boilers №№ 6, 7, 8 and 9).

Currently the boilers of the type LMZ (TKZ) 90/100 (№2 and 3) are mothballed. Steam boilers which are under operation are connected to the steam pipelines where the steam is distributed and supplied further to the turbines.

Current state of Kramatorsk HPP equipment is satisfactory and allows operation at least till 2017 inclusive, subject to scheduled repairs and timely technical maintenance.

The scheduled measures will improve the efficiency of fuel consumption and reduce own power consumption.

1) Reconstruction of turbine PT-60-90/13, station №3

Heating steam turbine PT-60-90/13 has nominal capacity of 60 MW. It was commissioned in 1973. The project foresees modernization the turbine's condensor. This measure implementation will reduce the pressure of exhausted steam of turbine by 0.01 kgf/cm². These measures will provide reduction of fuel consumption by 1192 tons of standard fuel per year.

2) Reconstruction of turbine PT-60-90/13, station №4

Heating steam turbine PT-60-90/13 has nominal capacity of 60 MW. It was commissioned in 1976. The project foresees replacement of control valves. Fuel saving after modernization of turbine will be 1166.5 tons of standard fuel per year (due to achieving of project parameters of steam distribution system).

3) Reconstruction of BKZ-160-100-PT boiler, station № 7

Currently the BKZ -160-100-PT № 7 boiler is using mixed fuel as the primary fuel (coal and gas spot lightning) with 76% efficiency. At the moment heavy fuel combustion in the boiler is not possible due to the technical state of the furnace cell's heating surface. It would be possible only if a major reconstruction is done. After the rehabilitation works the efficiency of boiler № 7 will increase to 85% in case of hard fuel combustion, Heating insulation of the boiler's gasproof furnace will be replaced as one of the measures of rehabilitation.

4) Reconstruction of BKZ-160-100-PT boiler, station №9

Currently the BKZ -160-100-PT № 7 boiler is using mixed fuel as the primary fuel (coal and gas spot lightning) with 76% efficiency. At the moment heavy fuel combustion in the boiler is not possible due to the technical state of the furnace cell's heating surface. It would be possible only if a major reconstruction is done. After the rehabilitation works the efficiency of boiler № 7 will increase to 85% in case of hard fuel combustion. Heating insulation of the boiler's gasproof furnace will be replaced as one of the measures of rehabilitation. Annual fuel savings achieved after the reconstruction will be 7480.5 t of standard fuel.

5) Reconstruction of cooling tower №1

The hot water from cooling equipment flows to water-cooling tower by the pipelines. The system of circulating water supply of Kramatorsk HPP is reverse with two cooling towers (№1, 2). The area of irrigation is 1600 m². Cooling tower has been commissioned in 1975. Today the cooling tower is under reconstruction. The existing cooling tower №2 can serve the needs of the power plant until at least 2017. Reconstruction of the cooling tower №1 will allow reduction of temperature of cooled water at the exit from cooling tower with the similar other conditions by 4-5 0C.

Use of cooling tower №1 will allow operating with load regimes similar to nominal – 40 MW during the summer period. The operation in this regime is more economically efficient by 4-5% than with the existing regime with loading 20-25 MW when cooling capacities of cooling tower №2 are utilized. Fuel savings will be 1519 tons of standard fuel per year.

6) Replacement of feeding electric pump, station №5 PE-150-145-2

The feeding pump #5 (similarly to the feeding pumps ## 6, 7, 8, 9) takes water from the plant's water collectors – the absorbing collector (6 kgf/cm²) and pumping collector (150 kgf/cm²). Electricity is

supplied to the feeding pump from the distribution equipment of the main distribution unit, and from the 6 kV distribution units which are used for the plant's own needs.

The replacement of feeding pump reduces electricity consumption. During the winter period two pumps PE-270-150 consume the total capacity of 2650 kWh; in case if one PE-270-150 or one PE-150-145 device is in operation, the total consumed capacity is 2075 kWh. In 2006 according to the annual power plant report the operational time of pumps in the single pump regime was 2400 hours. During the summer the pump PE-270-250 consumes total capacity of 1450 kWh, PE-150-145 consumes the capacity of 825 kWh. Annual operational period, taking into account maintenance stops, is 4200 hours. During the summer period electricity savings are expected to be 2002 MWh.

7) Modernization of hydraulic ash removal

As a result of modernization, 4 km-long pipeline (325 mm width) will be constructed replacing the existing dredging pump. Power savings constitute 3894 MWh per year.

8) Rehabilitation of district heating system in Kramatorsk

The envisaged rehabilitation of district heating system in Kramatorsk includes the following measures:

8.1. Replacement of old pipelines by new pipes covered by foamed polyurethane

The heat supply pipelines replacement will reduce actual heat losses from heat supply pipeline what will result in annual fuel savings of 1161 tons of standard fuel during 2008-2012.

8.2. Rehabilitation of boiler-rooms with replacement of capacitive heat exchangers by lamellar heat exchangers

Vapor-water capacitive heat exchangers STD 3068-3071 of six sizes (№ 1, 2, 3, 4, 5, 6) are used in the baseline scenario. These exchangers have changed their capacity during the lifetime. In 2008 capacitive heaters are to be replaced by lamellar at 35 substations. Heat exchangers are working in two stages; two lamellar heat exchangers are to be installed at each substation. During the first stage water is heated by heat carrier, returning from building heating systems (already exhausted of heat) to 30-40 oC. During the second stage the water is heated by heat carrier from pipeline rising the temperature to 50 oC. According to previous data in 2009 it is planned to install 40 heat exchangers, 65 heat exchangers in 2010, 60 heat exchangers in 2011. Expected electricity savings after the measure's implementation vary from 50 MWh in 2008 to 2486 MWh in 2011.

8.3. Major rehabilitation of boiler-rooms with replacement of pipes and valves

Physically exhausted and partially blocked pipes with hard to remove deposits in piped packages of network heaters are to be replaced by new pipes. Expected results of the measure:

- reduction of hydraulic resistance of boiler-rooms; reduction of electricity consumption for pumping of heat carrier (network water). This measure is expected to provide fuel savings of 48.9 tons of standard fuel per year.
- increase of heat generation by the heater by means of low-potential heat utilization with additional generation of power. This measure implementation is expected to result in fuel savings of 702 tons of standard fuel per year.

No changes into the reconstruction programme are foreseen throughout the whole project lifetime.

A.5. Title, reference and version of the baseline and monitoring methodology applied to the project activity:

A.5.1 Baseline methodology

For determination of the baseline the JI specific approach based on approved methodology ACM0002 «Consolidated methodology for grid-connected electricity generation from renewable sources» (version 10) is used.

A.5.2 Monitoring methodology

For monitoring of JI project the JI specific approach based on monitoring methodology ACM0002 «Consolidated methodology for grid-connected electricity generation from renewable sources» (version 10) is used.

A.6. Registration date of the project activity:

The JI project “Reconstruction of Kramatorsk HPP” has received the Letter of Approval from Ukraine, reference 1469/23/7 dated 04.12.2009. The Letter of Approval from investor country Germany dated 25.03.2010. The JI project has registration number UA1000156.

A.7. Crediting period of the project activity and related information (start date and choice of crediting period):

The length of crediting period is 120 months / 10 years of project lifetime

A.8. Name of responsible person(s)/entity(ies):

The persons responsible for the preparation of the Kramatorsk HPP monitoring report: the First deputy director, Mr. V.S. Potapenko (management); the Head of Production department Mr. A.M. Gusev (in charge for the report preparation).

SECTION B. Implementation of the project activity

B.1. Implementation status of the project activity

The status of implementation, including time table for major project parts is given in the Table 2 below:

Table 2. Status of implementation (according to the PDD version 2.2)

№	Measures	Beginning of design stage	Beginning of construction	Commissioning
1	Reconstruction of boiler № 7	–	September 2008	January 2009
2	Reconstruction of boiler № 9		April 2008	November 2008
3	Modernization of turbine PT-60-90/13 st. №3	September 2007	April 2008	August 2008
4	Modernization of turbine PT-60-90/13 st. №4	September 2008	April 2009	August 2009
5	Reconstruction of cooling tower № 1	May 2006	June 2008	September 2008
6	Capital repair of boiler-rooms with replacement of tubes and valves	April 2008	June 2008	November 2008
7	Replacement of capacitive heat exchangers by lamellar - 35 units	May 2008	July 2008	November 2008
	40 units	May 2009	July 2009	November 2009
	65 units	May 2010	July 2010	November 2010
	60 units	May 2011	July 2011	November 2011
8	Replacement of heat supply pipelines by pipelines from polyurethane foam	June 2008	June 2008 2009 2010 2011 2012	November 2008 2009 2010 2011 2012
9	Replacement of the feeding pump	-	May 2007	April 2009

Due to lack of finances, there was no replacement of capacitive heat exchangers by lamellar ones in 2010.

In 2010 at HPP there were a number of technical breakdowns. The detailed information as to the technical breakdowns is given in Annex 2.

B.2. Revision of the monitoring plan

There are no deviations to the registered monitoring plan.

B.3. Request for deviation applied to this monitoring period

No deviations compared to the registered version of the monitoring plan are expected.

B.4. Notification of request of approval of changes

There are no changes from the project activity.

SECTION C. Description of the monitoring system

C.1. Monitoring and control system

The control and monitoring system is divided into three main parts:

- 1) Electrical measurement;
- 2) Heat measurement;
- 3) Fuel measurement (natural gas, coal).

Electrical measurement

For this project the following electrical measurements are necessary: total generated power, power consumption for the own needs of HPP, power supplied to the consumers.

There are 3 commercial electricity meters at the HPP which measure the electricity generated by turbines.

There are more than one hundred technical and commercial electricity meters which measure power supplied to the consumers and consumption for the own needs of HPP.

Generated power and power supplied to the consumers is present in the reports on generation and supply to the grid and in the extracts from registration journal of the HPP as well as in the reports on power distribution.

Heat measurement

The HPP is equipped with heat measurement devices, which allow determining the amount of heat supplied to the consumers. The amount of heat generated at the HPP is also present in the journal of heat supplied to the consumers.

Determination of heat economy from heating system reconstruction is executed on the basis of calculation of decrease in thermal energy consumption through restored thermal insulation and reduction of network water consumption. Data on heat supply to the consumers from boiler-rooms is saved in the journal of accounting of heat supplied to the consumers (boiler-rooms' data).

To determine the amount of heat generated by boilers №№ 7, 9 the data on generated steam by these boilers is used. The HPP is equipped by special flow-meters which measure the amount of generated steam by boilers №№ 7, 9.

Measurement of fuel consumption (natural gas, coal)

Measurement of natural gas consumption

The volume of consumed gas is measured by means of "Universal-02" gas flow meter. The meter's software is intended for transformation of the incoming signals from the gas flow meters, vortex converters of consumption, transformation and measuring of incoming signals from converters of measured pressure and gas temperature, calculation and reduction with accordance to conditions set in GOST 2939-63 (standard conditions) of its volume and volume consumption. "Universal-02" gas flow meter is allowed for serial production and use in Ukraine and is entered into state register under the reference Y759-01.

"Universal-02" gas flow meter keeps in its memory the archives of parameters which are combined into hourly and daily archives of energy carriers' consumption, emergency cases and access to the operative memory device with possibility of its transfer to a PC via RS232 or RS485 interfaces for further processing and printing.

Data on quality of natural gas (physical and chemical indicators) are put into the program “Universal-02” manually according to a quality passport or a telephone message (in case of indicators changes) given by Kramatorsk Department of gasification and gas supply.

The supply reports of natural gas, diagrams of fuel and journals of fuel accounting are used for cross-checking the amount of consumed natural gas.

Measurement of coal

In 2010 the arrival of coal had been controlled by two scales. The RS-150C13V, which was leased from Novokramatorsk machine building plant (NKMB) controls the compliance of coal arrival with accompanying forms before beginning the unloading. The conveyer scales KNV-2D-2R is used to control the coal consumption.

The scheme of measuring devices location which controls the abovementioned parameters is given below in Figure 1.

C.2. Information on equipment used

Electricity measurements

For this project the measurement of the following electrical parameters are necessary: total generated power, power consumption for own needs of HPP, power supplied to consumers.

The measurement of generated power

In Table 3 the data on meters which measure generated power is given.

Table 3. Data on meters for generated power measurement

Serial number	Installed at	Data as of 01.01.2011	Data as of 01.01.2010	Difference	Coefficient	Power, kWh
36132321	Generator -2	0	0	0	480	0
36132304	Generator -3	4811643	3296852	1514791	96	145419936
36130059	Generator -4	4416164	2585573	1830591	96	175736736

Serial number	Installed at	Accuracy rate, %	Installation date	Date of last calibration	Date of next calibration	Remarks
36132321	Generator -2	0.2	26.01.2009	3rd quarter 2007	3rd quarter 2013	
36132304	Generator -3	0.2	26.01.2009	3rd quarter 2007	3rd quarter 2013	
36130059	Generator -4	0.2	26.01.2009	3rd quarter 2007	3rd quarter 2013	

All accounting meters in the Table 3 were installed as backup meters in 2008. They are in status of commercial use since 26.01.2009. The calibration period of these meters is once every 6 years.

Measurement of power supplied to consumers

In the Table 4 data on the balance of power supply is given. The detailed data as to the meters used and their appropriate readings is given in Annex 1. Power consumption for own needs of HPP is calculated as difference between generated power and power supplied to the consumers from the plant buses.

Table 4. Power supply balance

Parameter	2010
Power generation by generators, kWh	321 156 672
Power supply to the grid and consumers, kWh	430 112 152
Power consumption from the grid, kWh	165 045 906
Total supply from busbars	265 066 246

Heat measurement

Data on measurement devices for heat supplied to the consumers from Kramatorsk HPP is given in the Table 5.

The measurement of heat supplied to the consumers

Table 5. Data on flow meters of heat supplied to consumers

Measurement device	Producer (company, country)	Work parameter	Serial number	Accuracy rate %	Installation date	Generated heat, Gcal	Date of last calibration	Date of next calibration	Remark
1	2	3	4	5	6	7	8	9	10

Additional feeding HWCP №3 SVTU-10M Supply HWCP №3 SVTU -10M	Kyiv, Company «Sempal Ko Ltd»	Heat	12018	2,0	21.11.08	3800	07.05.07	07.05.11	The amount of generated heat is received as accumulated result per year
		Heat	14295	2,0	21.11.08	91875	04.08.08	04.08.12	
Additional feeding HWCP №4 SVTU-10M Supply HWCP №4 SVTU-10M	Kyiv, Company «Sempal Ko Ltd»	Heat	11815	2,0	21.11.08	3197	07.05.07	07.05.11	The amount of generated heat is received as accumulated result per year
		Heat	14357	2,0	21.11.08	62504	04.08.08	04.08.12	
Additional feeding HWCP №5 SVTU-10M Supply HWCP №5 SVTU-10M	Kyiv, Company «Sempal Ko Ltd»	Heat	14135	2,0	21.11.08	6170	24.06.08	24.06.12	The amount of generated heat is received as accumulated result per year
		Heat	14262	2,0	21.11.08	135006	05.08.06	05.08.12	
Additional feeding HWCP №6 SVTU -10M Supply HWCP №6 SVTU-10M	Kyiv, Company «Sempal Ko Ltd»	Heat	11757	2,0	21.11.08	10839	07.05.07	07.05.11	The amount of generated heat is received as accumulated result per year
		Heat	14390	2,0	21.11.08	239347	05.08.08	05.08.12	
Additional feeding HWCP № 2 SVTU-10M	Kyiv, Company «Sempal Ko Ltd»	Heat	11911	2,0	21.11.08	2094	07.05.07	07.05.11	The amount of generated heat is received as accumulated result per year
Heat energy supply to NKMP Additional feeding : Leakage	«Spetsysteme» Belorus	Water consumption for additional feeding	0609009	0,4	14.12.06	79615	19.10.10 ¹	19.10.14	Passport
UVR-011	Kharkiv city, JSC «Tahion»	Network water consumption	1080	1,0	14.12.06		09.08.10	09.08.12	Passport
TSP-Metran-206 TSP-Metran-206	CJSC PG «Metran»	Temperature of network water	565545 565546	B B	14.12.06 14.12.06		02.08.10 02.08.10	02.08.11 02.08.11	Passport Passport

¹ The boiler № 1 was not in operation within period from 28.09.2010 to 19.10.2010. The heating season of CJSC "NKMP" started from 01.11.2010.

Data on the amount of steam generated by boiler №№ 7, 9 is used for calculation of heat generated by boilers №№ 7, 9. Information on measuring devices for steam generated by boilers №№ 7, 9 is given in the Table 6.

Table 6. Data on flow meters of steam generated by boiler №№ 7, 9

Measurement device	Producer (company, country)	Work parameter	Serial number	Accuracy rate %	Installation date	Data 01.01.2008	Steam generated by boilers №№7,9	Date of last calibration	Date of next calibration	Remarks
Boiler №7 Secondary RP160-09 Primary DM 3583 M	Ukraine, Lviv	Superheated vapour	1120476 12048	1,0 1,5	10.09.08	No summator	546759	10.06.10	10.06.11	Passport
Boiler №9 Secondary RP160-09 Primary DM 3583 M	Ukraine, Lviv	Superheated vapour	2091175 14176	1,0 1,5	15.02.01	No summator	609672	07.10.10 ²	07.10.11	Passport

Fuel measurement

Natural gas measurement

Data on “Universal-02” gas flow meter is given in the Table 7.

Table 7. Data on “Universal-02” natural gas flow meter

Measurement device	Producer (company, country)	Work parameter	Serial number	Accuracy rate %	Installation date	Natural gas consumption, ths. m ³	Date of last calibration	Date of next calibration	Remarks
Universal-02	GVP «GREMPIS», Ltd. Vinnitsa Ukraine	Natural gas consumed by boilers	5672	0,2	02.09.07	61902	29.07.09	29.07.11	Passport

Coal measurement

In 2010 the coal consumption had been measured by two scales. Data on RS-150C13V mechanical car scale used for consumed coal measuring is given in Table 8. Data on conveyer scale KNV-2D-2R used for consumed coal measuring is given in Table 9.

Table 8. Data on RS-150C13V mechanical car scale for measuring of coal amount

Measuring device	Producer (company, country)	Work parameter	Serial number	Installation date	Coal consumption, t	Date of last calibration	Date of next calibration
RS-150C13V mechanical car scale	Odessa, Ukraine	Coal consumption	0011	12.05.09	173030	24.11.10 ³	24.11.11

² The planned device calibration was appointed on 11.09.2010, the actual calibration was performed 07.10.2010. Within period from 11.09.2010 to 07.10.2010, the devices kit was in general repair. During the repair, the boiler №9 was equipped with the calibrated accounting devices kit from the boiler №7.

³ Calibration of the mechanical car scale is performed once every 6 months; only last calibration date is specified in the table. Date of previous calibration is 28.05.2010.

Table 9. Data on conveyer scale KNV-2D-2R for measuring of coal consumption

Measuring device	Producer (company, country)	Work parameter	Serial number	Installation date	Coal consumption, t	Date of last calibration	Date of next calibration
conveyer scale KNV-2D-2R	Dnipropetrovsk Ukraine	Coal consumption	09178	01.04.09	173030	03.08.10	03.08.11

C.3. Calibration procedure

For power meters

Data on calibration of meters used for measuring of total power generation is given in the Table 10.

Table 10. Data on calibration of electricity meters for total power generation

Parameter	Answer (passport data)
Interval between calibrations	6 years
Methodology of procedure of calibration of meters of total power generation	Methodology of Ukrainian Center on standardization and metrology
Period of warranty from the producer	18 months (SL7000)
Body responsible for calibration and certification of the measuring equipment	Methodology of Ukrainian Center on standardization and metrology

Data on calibration of electricity meters used for measuring power consumption for own needs of HPP is given in the Table 11.

Table 11. Data on calibration of electricity meters used for measuring of power consumed for own needs of HPP

Parameter	Answer (passport data)
Interval between calibrations	6 years
Methodology of procedure of calibration of meters of power consumed for own needs	Methodology of Methodology of Ukrainian Center on standardization and metrology
Period of warranty from the producer	18 months (SL7000)
Body responsible for calibration and certification of the measuring equipment	Ukrainian Center on standardization and metrology

Data on calibration of electricity meters used for measuring of power supplied to consumers is given in the Table 12.

Table 12. Data on calibration of electricity meters used for measuring of power supplied to consumers

Parameter	Answer (passport data)
Interval between calibrations	6 years
Methodology of procedure of calibration of meters of power supplied to consumers	Methodology of Ukrainian Center on standardization and metrology
Period of warranty from the producer	18 months (SL7000)
Body responsible for calibration and certification of the measuring equipment	Ukrainian Center on standardization and metrology

Measuring devices of heat and generated steam

Data on calibration of flow-meters used for generated steam by boilers №№ 7, 9 is given in the Table 13.

Table 13. Data on calibration of flow meters used for measuring steam generation by boilers №№ 7, 9.

Parameter	Answer (passport data)
Interval between calibrations	1 year
Methodology of procedure of calibration of flow-meters of steam generation	Methodology of State standard
Period of warranty from the producer	1 year
Body responsible for calibration and certification of the measuring equipment	Derzhstandartmetrologiya

Data on calibration of meters for measuring generated heat is given in the Table 14.

Table 14. Data on calibration of heat meters of generated heat

Parameter	Answer (passport data)
Interval between calibrations	4 years
Methodology of procedure of calibration of meters of heat generation	Methodology of calibration testing is ShIMN.407251.003 I2
Period of warranty from the producer	48 months
Body responsible for calibration and certification of the measuring equipment	Derzhstandartmetrologiya

*Fuel measuring devices**Measuring of natural gas amount*

Data on calibration of “Universal-02” natural gas flow meter is given in the Table 15.

Table 15. Data on calibration on “Universal-02” natural gas flow meter

Parameter	Answer (passport data)
Interval between calibrations	2 years
Methodology of procedure of calibration of flow-meters of natural gas consumption	Methodology of state metrological attestation GREM.02 0000.001-01.01 PMA and guidance on operation
Period of warranty from the producer	18 months
Body responsible for calibration and certification of the measuring equipment	Derzhstandartmetrologiya

Measuring of coal consumption

Data on calibration of RS-150C13V mechanical car scale is given in the Table 16.

Table 16. Data on calibration of RS-150C13V mechanical car scale

Parameter	Answer (passport data)
Interval between calibrations	1 year
Methodology of procedure of calibration of meters of coal consumption	Calibration testing is done by balance receiver.
Period of warranty from the producer	15 years
Body responsible for calibration and certification of the measuring equipment	Derzhstandartmetrologiya

C.4. Involvement of Third Parties
--

Ukrainian Centre on standardization and metrology was involved as a Third Party.

C.5. Data collection (accumulated data for whole monitoring period)
--

The structure of operation and management of the project is given in the PDD in the Figure 2 “Scheme of data collection according to the monitoring plan”.




Figure 2. Data collection for the monitoring

SECTION D. Data and parameters
D.1. Data and parameters determined at registration and not monitored during the monitoring period, including default values and factors

A number of parameters that are not monitored by the metering equipment are used for the calculations. These parameters are listed below.

Data / Parameter:	<i>CEF_{coal}</i>
Data unit:	t C/ TJ
Description:	Carbon emission factor for coal (anthracite)
Source of data used:	Section 2 of IPCC Guidelines for National Greenhouse Gas Inventories, 1996 (Volume 2 (Energy), page 1.6, table 1-2)
Value(s) :	26.8
Indicate what the data are used for (Baseline/ Project/ Leakage emission calculations)	Calculation of the baseline and project scenario emissions
Additional comment:	

Data / Parameter:	<i>CEF_{natural gas}</i>
Data unit:	t C/ TJ
Description:	Carbon emission factor for natural gas
Source of data used:	Section 2 of IPCC Guidelines for National Greenhouse Gas Inventories, 1996 (Volume 2 (Energy), page 1.6, table 1-2)
Value(s) :	15.3
Indicate what the data are used for (Baseline/ Project/ Leakage emission calculations)	Calculation of the baseline and project scenario emissions
Additional comment:	

Data / Parameter:	<i>CEF_{electricity}</i>
Data unit:	kg CO ₂ e/ kWh
Description:	Carbon emission factor of the electric grid of Ukraine
Source of data used:	State Environmental Investment Agency of Ukraine, Order # 43 dated 28/03/2011
Value(s) :	1.067
Indicate what the data are used for (Baseline/ Project/ Leakage emission calculations)	Calculation of the baseline and project scenario emissions
Additional comment:	

D.2. Data and parameters monitored

Parameters monitored for the calculation of the project scenario emissions are presented below in the Table 17. Parameters monitored for the calculation of the project scenario emissions are presented below in the Table 18.

Table 17. Data collected in order to monitor emissions under the project scenario

ID number <i>(Please use numbers to ease cross-referencing to D.2.)</i>	Data variable	Source of data	Data unit	Measured (m), calculated (c), estimated (e)	Recording frequency	Proportion of data to be monitored	How will the data be archived? (electronic/paper)	Comment
K1	Coal consumption	Meter of consumed fuel, diagram, Journal of registration data of consumed fuel	Tons	M	Monthly	100%	Electronic/paper	The primary data source weighting of coal on the weighbridge; secondary data source is the fuel diagram.
K2	Net calorific value of coal	Report of the Supplier, analytical report of chemical analysis laboratory	kcal/kg	E	Monthly	100%	Electronic/paper	In the invoices of fuel supplier, report of chemical analysis laboratory
K4	Natural gas consumption	Meter of consumed fuel, diagram, Journal of registration	Ths. m ³	M	Monthly	100%	Electronic/paper	Fuel consumption by boilers is the main data which allows calculation of GHG emissions in the reporting year

		data of consumed fuel						
K5	Net calorific value of natural gas	Report of the Supplier, analytical report of chemical analysis laboratory	kcal/kg	E	Monthly	100%	Electronic/paper	In the passport of fuel from fuel supplier
K7	Power generation	Meters of Kramatorsk HPP, balance data	kWh	M, C	Monthly	100%	Electronic/paper	Annual report
K8	Own Electricity consumption	Meters of KramatorskHPP, calculation of consumed amount	kWh	M, C	Monthly	100%	Electronic/paper	Annual report
K9	Power supplied to customers (to the grid)	Meters of Kramatorsk HPP, balance data	kWh	M, C	Monthly	100%	Electronic/paper	Annual report
K11	Steam generation	Meters of Kramatorsk HPP	Gcal	M	Annually	100%	Electronic/paper	Annual report
K12	Heat supplied to consumers	Meters of Kramatorsk HPP, balance data	Gcal	M, C	Annually	100%	Electronic/paper	Annual report
K13	Length of the heat pipes	Reports	m	M, C	Annually		Electronic/paper	Annual report

	replaced by pipes in poliurethane foam in the year y							
--	--	--	--	--	--	--	--	--

Table 18. Data collected in order to monitor emissions under the baseline scenario

ID number <i>(Please use numbers to ease cross-referencing to D.2.)</i>	Data variable	Source of data	Data unit	Measured (m), calculated (c), estimated (e)	Recording frequency	Proportion of data to be monitored	How will the data be archived? (electronic/paper)	Comment
K1	Coal consumption	Meter of consumed fuel, diagram, Journal of registration data of consumed fuel	Tons	M	Monthly	100%	Electronic/paper	The primary data source weighting of coal on the weighbridge; secondary data source is the fuel diagram.
K2	Net calorific value of coal	Report of the Supplier, analytical report of chemical analysis laboratory	kcal/kg	E	Monthly	100%	Electronic/paper	In the invoices of fuel supplier, report of chemical analysis laboratory)
K4	Natural gas consumption	Meter of consumed fuel, diagram,	Ths. m ³	M	Monthly	100%	Electronic/paper	Fuel consumption by boilers is the main data which allows calculation of GHG emissions in the reporting year

		Journal of registration data of consumed fuel						
K5	Net calorific value of natural gas	Report of the Supplier, analytical report of chemical analysis laboratory	kcal/kg	E	Monthly	100%	Electronic/ paper	In the passport of fuel from fuel supplier
K7	Power generation	Meters of Kramatorsk HPP, balance data	kWh	M, C	Monthly	100%	Electronic/ paper	Annual report
K8	Own Electricity consumption	Meters of KramatorskHPP, calculation of consumed amount	kWh	M, C	Monthly	100%	Electronic/ paper	Annual report
K9	Power supplied to customers (to the grid)	Meters of Kramatorsk HPP, balance data	kWh	M, C	Monthly	100%	Electronic/ paper	Annual report
K11	Steam generation	Meters of Kramatorsk HPP	Gcal	M	Annually	100%	Electronic/ paper	Annual report
K12	Heat supplied to consumers	Meters of Kramatorsk HPP, balance data	Gcal	M, C	Annually	100%	Electronic/ paper	Annual report

K13	Length of the heat pipes replaced by pipes in poliurethane foam in the year y	Reports	m	M, C	Annually		Electronic/ paper	Annual report
------------	---	---------	---	------	----------	--	----------------------	---------------

D.2.1 Accuracy level of the measurement equipment

Accuracy level of the measurement equipment

Every type of measurement equipment has its defined accuracy level. As a rule, this level is low. The accounting for inaccuracies at the HPP is regulated by the 'Instruction on the rules for commercial accounting of electricity', which is an integral part of the current agreement between the members of the Wholesale electricity market of Ukraine. The inaccuracy level of the electricity measurement devices is kept below 0.5%.

The measurement equipment used for commercial accounting of Kramatorskteploenergo LLC are in compliance with the accuracy level mentioned above. The accuracy of the fuel volumes received by Kramatorskteploenergo LLC is stated in the relevant certificates provided by the supplier; the forms of these certificates are agreed between the consumer, suppliers and with the State Enterprise Derzhstandartmetrologiya (based in Donetsk and Dnipropetrovsk). For the natural gas measurements the accuracy level is 1%, for the hard fuel – 1.5%.

Therefore, the acceptable level of the inaccuracy of the measurements, for which no correction is necessary within the calculations provided below, is set.

D.2.2 Quality assurance and quality control measures

Documented procedures and management plan

Roles and responsibilities

The general project management is done by the General Director of Kramatorsk HPP and the First Deputy Director. The Director manages and coordinates activity of all departments. Every parameter is monitored by the respective department headed by the Head of the department.

The organizational structure of the data collection at Kramatorsk HPP is presented above in the Section C.

Training

With the purpose of operation of modernized equipment of Kramatorsk HPP the studying of 6 people of operational personnel of Kramatorskteploenergo LLC was done at the boiler equipment of the type BKZ-220 of Chernihiv HPP. The cost of training is UAH 21 000.

Internal audit and control measures

A system of technical tools 'KTS Energiya' is used at Kramatorsk HPP as the main internal control instrument. The system is managed by the department of information technologies and communication. The data is collected with the minimum range of 5 minutes for each technological parameter. The system archives the information collected and keeps the archived data for at least one year. The data is collected by the accounting group of the production department.

Information on the social and environmental impacts of the project

As a result of the project implementation, the local community and the employees of Kramatorsk HPP will have secure workplaces for the long-term perspective, due to the stable operation of the plant. The consumption of the fossil fuels for heat and power generation will be reduced. The project's implementation will lead to reduction of greenhouse gas and other toxic gases (such as carbon monoxide and nitrogen oxides) emission to the atmosphere. Reducing the amount of greenhouse gas emissions would allow to prevent their further accumulation in the atmosphere and therefore contribute to the climate change mitigation.

D.3. Data and parameters used to calculate leakage emissions

Leakages are not foreseen.

D.4. Other relevant data and parameters
--

External data (type of data, source, access)

In accordance with PDD the following external data were used in the project in 2010.

Parameter	Source	Access
Net calorific value of coal	Report of the Supplier	Fuel supplier certificates are kept at Kramatorskteploenergo LLC
Carbon emission factor for coal	IPCC Guidelines for National Greenhouse Gas Inventories (Volume 2 (Energy), 1996)	Publicly available
Net calorific value of natural gas	Report of the Supplier.	Fuel supplier certificates are kept at Kramatorskteploenergo LLC
Carbon emission factor for natural gas	IPCC Guidelines for National Greenhouse Gas Inventories (Volume 2 (Energy), 1996)	Publicly available
Carbon emission factor of the electric grid of Ukraine	Carbon emission factor for national grid of Ukraine is given in Order # 43 dated 28/03/2011, issued by State Environmental Investment Agency of Ukraine	Publicly available

SECTION E. Emission reductions calculation

E.1. Baseline emissions calculation

The following formula is used for calculating the baseline emissions at Kramatorsk HPP (BE_y):

$$BE_y = BE_{FC,elec,y} + BE_{electricity,y} + BE_{heat_ex}$$

where:

$BE_{FC,elec,y}$ – baseline emissions from the fuel combusted at the power plant for heat and power production in the absence of project measures, t CO₂. Emissions from different fuel types are calculated by multiplying the amount of the fuel of the type 'i' by the carbon emission factor (t CO₂ / t (1000 m³)) for the fuel I consumed during the year y.

$BE_{electricity,y}$ – baseline emissions from the grid electricity to be replaced due to the project implementation at the power plant, t CO₂.

BE_{heat_ex} – baseline emissions from electricity consumption by the boilers, where the heat exchangers are to be replaced, t CO₂.

Baseline emissions for the scenario of absence of the project measures are given in the Table 19 below.

Table 19. Baseline emissions, t CO₂e

Year	2010
Baseline emissions, t CO ₂ e	376 642

E.2. Project emissions calculation

Project emissions (E_p) are calculated by the following formula:

$$E_p = PE_{FC,elec,y} + PE_{heat_ex}$$

where:

$PE_{FC,elec,y}$ – project emissions from the actual fuel consumed by the power plant for the heat and power production (savings from heat distribution network rehabilitation are not taken into account), t CO₂.

PE_{heat_ex} – project emissions from electricity consumption by the boiler rooms where the heat exchangers are to be replaced, t CO₂.

The emissions after implementation of the project measures are presented below in Table 20.

Table 20. Project emissions, t CO₂e

Year	2010
Emissions, t CO ₂ e	353 022

E.3. Leakage calculation

No leakage is expected within the project.

E.4. Emission reductions calculation / table

Emission reductions due to the project implementation are calculated as the difference between the baseline and the project emissions.

Emission reductions due to the project implementation are given in the Table 21 below.

Table 21. Emission reductions

Year	2010
Emission reductions resulting from HPP modernization, t CO ₂ e	22 894
Emission reductions resulting from modernization of heat supply systems, t CO ₂ e	726
Total emission reductions, t CO₂e	23 620

E.5. Comparison of actual emission reductions with estimates in the PDD

Comparison of actual emission reductions with estimates in the registered PDD is given in the Table 22 below

Table 22. Comparison of emission reductions

Item	Values applied in ex-ante calculation of the registered PDD	Actual values reached during the monitoring period
Emission reductions (tCO₂e)	67 782	23 620

Compared to reductions estimated in the registered PDD, project emission reductions have decreased by 45 689 tCO₂e

E.6. Remarks on difference from estimated value in the PDD

The amount of generated electric and heat power in the baseline and project scenario pointed in the registered PDD has been changed. It happened because during the PDD development the expected data for 2010 has been given, which differs from actual data in 2010. In the Table 23 actual data on heat and power generation in 2010 is given.

Table 23. Heat and power generation for baseline scenario for the project

Item	2010
Power generation, MWh	321 157
Heat generation, Gcal	580 599

Annex 1. Data as to the meters of measurement of power supplied to consumers

Serial number	Installed at	Data as of 01.01.2011	Data as of 01.01.2010	Difference	Coefficient	Power, kWh	Notes
a) Power supply (Total: 430 112 152 kWh)							
01073888	Section LIP 1	12795	0	12795	132	1 688 940	
01073888	Section LIP 1	63544	25505	38039	132	5 021 148	Reprogramming
01076223	Section LIP 2	24737	0	24737	132	3 265 284	
01076223	Section LIP 2	112322	73826	38496	132	5 081 472	Reprogramming
	Section LIP 2					6 540	Shortage
01083013	Section Druzhkovka 1	16453	0	16453	132	2 171 796	
01083013	Section Druzhkovka 1	187254	73250	114004	132	15 048 528	Reprogramming
01054389	Section Druzhkovka 2	29480	0	29480	132	3 891 360	
01054389	Section Druzhkovka 2	116019	50513	65506	132	8 646 792	Reprogramming
	Section Druzhkovka 2					6 016	Shortage
01076236	Section Kujbisheva 1	116121	0	116121	88	10 218 648	
01082976	Section Kujbisheva 1	380455	120816	259639	88	22 848 232	Replacement
01076228	Section Kujbisheva 2	137227	0	137227	66	9 056 982	
01076228	Section Kujbisheva 2	217581	0	217581	66	14 360 346	Reprogramming
01083001	Section Kujbisheva 2	3810019	3743340	66679	66	4 400 814	Replacement
	Section Kujbisheva 2					2 112	Shortage
	Section Kujbisheva 2					11 401	Shortage
01166656	Section NKMZ-110	2134662	1695179	439483	66	29 005 878	
01166657	PGV-3	1136835	624494	512341	132	67 629 012	
	PGV-3					16 600	Shortage
36132295	Section ShSMV			0	1320	0	Maintenance
36118861	Section LEP-1 35 kV	222651	149220	73431	140	10 280 340	
36118862	Section LEP-1 35 kV	289628	201382	88246	140	12 354 440	
1146216	Section Drozhzhevoj 1	25570	6316	19254	3,6	69 314	
36118833	Section Drozhzhevoj 2	243	243	0	24	0	
01030346	Section CRP 1	262812	261416	1396	72	100512	Replacement
38118775	Section CRP 1	13240	12797	443	72	31896	
01030369	Section CRP 4	987715	918987	68728	72	4948416	Replacement
36118851	Section CRP 4	207782	192378	15404	72	1109088	
01030353	Section Jel. pech' 10	440561	244222	196339	72	14136408	Replacement
36118771	Section Jel. pech' 10	669778	638726	31052	72	2235744	
01030367	Section RP1 ceh 11	430060	374249	55811	72	4018392	Replacement

36118781	Section RP1 ceh 11	84088	71602	12486	72	898992	
01030368	Section Pidstancija 11	425778	378044	47734	72	3436848	Replacement
36118802	Section Pidstancija 11	97574	87971	9603	72	691416	
01030365	Section Pidstancija 9	580365	540029	40336	96	3872256	Replacement
36118813	Section Pidstancija 9	160620	137375	23245	96	2231520	
01030352	Section Pidstancija 17	314356	313873	483	72	34776	Replacement
36118752	Section Pidstancija 17	107609	106862	747	72	53784	
01030361	Section Pidstancija 8-1	555809	555635	174	72	12528	Replacement
36118803	Section Pidstancija 8-1	101314	101170	144	72	10368	
01030355	Section Pidstancija 3-1	129282	120582	8700	72	626400	Replacement
36118823	Section Pidstancija 3-1	44973	43343	1630	72	117360	
01030364	Section CRP 2	803409	646301	157108	72	11311776	Replacement
36118842	Section CRP 2	373828	353588	20240	72	1457280	
01030372	Section Pidstancija 6	94404	76217	18187	72	1309464	Replacement
36118841	Section Pidstancija 6	24833	24833	0	72	0	
01030366	Section Kompressornaja 1	675679	611916	63763	72	4590936	Replacement
36118863	Section Kompressornaja 1	210950	201678	9272	72	667584	
01030362	Section Pidstancija 7	607568	577885	29683	72	2137176	Replacement
36118853	Section Pidstancija 7	36776	36776	0	72	0	
01030371	Section Pidstancija 3-2	388125	260228	127897	72	9208584	Replacement
36118843	Section Pidstancija 3-2	217042	197507	19535	72	1406520	
01030354	Section Pidstancija 5	259661	237850	21811	72	1570392	Replacement
36118811	Section Pidstancija 5	52340	48251	4089	72	294408	
01030356	Section Pidstancija 8-2	981725	897972	83753	72	6030216	Replacement
36118781	Section Pidstancija 8-2	332085	315323	16762	72	1206864	
01030359	Section Jel. pech'6	913801	773782	140019	90	12601710	Replacement
36118842	Section Jel. pech'6	514142	490700	23442	90	2109780	
01030345	Section RP 25	529849	506858	22991	180	4138380	Replacement
36118793	Section RP 25	92364	85521	6843	180	1231740	
01161590	RP 70	2495475	1243167	1252308	7,2	9016617,6	
01030348	Section of process water pump 4	758154	758154	0	12	0	Replacement
36118822	Section of process	123907	123907	0	12	0	

	water pump 4						
01030357	Section of process water pump 5	145874	58852	87022	18	1566396	Replacement
36118812	Section of process water pump 5	228894	215364	13530	18	243540	
01030344	Section Skvazhina 20	1455856	118908	1336948	0,4	534779	
36125811	Heating water pump #1	2839955	897672	1942283	0,9	1748055	
36125802	Heating water pump #2	2729294	1477714	1251580	1,2	1501896	
36125828	Heating water pump #3	1774995	949482	825513	1,8	1485923	
36125815	Heating water pump #4	423535	268167	155368	7,2	1118650	
36125803	Heating water pump #5	828140	534941	293199	1,2	351839	
36125804	Heating water pump #6	854197	520063	334134	1,2	400961	
36125826	Heating water pump #7	2305663	905859	1399804	1,2	1679765	
36125827	Heating water pump #9	848009	231527	616482	1,8	1109668	
36125813	Heating water pump #10	1693129	1679192	13937	1,2	16724	
36125818	Heating water pump #11	2308514	922449	1386065	1,2	1663278	
36125816	Heating water pump #12	3002584	1842209	1160375	1,8	2088675	
36125812	Heating water pump #13	2816335	1689199	1127136	1,8	2028845	
36125817	Heating water pump #14	615785	424329	191456	1,8	344621	
36125814	Heating water pump #15	3754246	2002924	1751322	1,8	3152380	
36125820	Heating water pump #16	1574020	958022	615998	1,8	1108796	
36125819	Heating water pump #17	1876498	1295552	580946	1,8	1045703	
36118511	Feedwater pump #1	564361	521430	42931	0,03	1288	
36118531	Feedwater pump #2	2129840	1423020	706820	0,03	21205	
36115851	Feedwater pump #3	10098847	6222413	3876434	0,03	116293	
36118476	Feedwater pump #4	0	0	0	0,03	0	
36118521	Feedwater pump #6	4155653	4123017	32636	0,03	979	
36118501	Feedwater pump #7	5440869	3561843	1879026	0,04	75161	
36118481	Feedwater pump #8	4360615	3853587	507028	0,03	15211	
36118506	Feedwater pump #1	9630793	3359501	6271292	0,03	188139	
36118534	Feedwater pump makeup demineralizer #2	25206688	16669170	8537518	0,03	256126	

36118541	Feedwater pump makeup demineralizer #3	6366542	5419196	947346	0,03	28420	
36118486	K N B #1	103	99	4	0,04	0	
36118533	K N B #2	35611	33	35578	0,04	1423	
36118491	K N B #3	11418777	5049109	6369668	0,04	254787	
36118561	K N B #4	2999554	1425154	1574400	0,04	62976	
36118544	K N B #5	9376468	6331440	3045028	0,04	121801	
36118555	K N B #6	1604302	884564	719738	0,04	28790	
36118553	K N B #7	9725888	7308451	2417437	0,04	96697	
36118545	K N B #8	2021823	2010917	10906	0,04	436	
36118536	K N B #9	15788229	9776750	6011479	0,04	240459	
36118496	K N B #10	6885260	2462508	4422752	0,04	176910	
01136239	Section NIIPTMash 1	1840555	1840555	0	7,2	0	
01136221	Section NIIPTMash 2	0	0	0	720	0	
01136264	Section NIIPTMash 3	1584890	1217218	367672	12	4412064	
01146357	Section NIIPTMash 4	622793	207461	415332	12	4983984	
53002442	JSC "Novij Mir"	108388	27514	80874	0,2	16175	
53064228	Chiller #2 (backup)	237255	0	237255	0,16	37961	
0191723	Modul-Invest	8843	1378	7465	0,1	747	
01146232	LLC "Urozhay"	4239287	2910963	1328324	2,4	3187978	
36148143	Amstor-1	2016327	904118	1112209	1,2	1334651	
36148144	Amstor-2	1671945	736877	935068	1,8	1683122	
4848598	LLC "Astelit"	284696	142946	141750	0,1	14175	
36660	UMC-1	14796845	8524342	6272503	0,01	62725	
36601	UMC-2	6971830	4677409	2294421	0,01	22944	Replacement
0385629	UMC-2	8792	111	8681	0,1	868	
4848601	CSC "Kyivstar GSM"	768115	530980	237135	0,1	23714	
01113967	JSC "SKMZ"	1737239	1737239	0	7,2	0	
01146326	Otd.Socgorod 1	265869	0	265869	7,2	1 914 257	
01146326	Otd.Socgorod 1	862082	103082	759000	7,2	5 464 800	Reprogramming
01136130	Otd.Socgorod 2	410402	0	410402	7,2	2 954 894	
01136130	Otd.Socgorod 2	1179488	272849	906639	7,2	6 527 801	Reprogramming
01136198	Otd.Socgorod 3	342444	0	342444	7,2	2 465 597	
01136198	Otd.Socgorod 3	4774000	3918602	855398	7,2	6 158 866	Reprogramming
01136102	Otd.Socgorod 4	332142	0	332142	7,2	2 391 422	
01136102	Otd.Socgorod 4	4218982	3361230	857752	7,2	6 175 814	Reprogramming
01136179	Otd.Socgorod 5	170390	0	170390	12	2 044 680	
01136179	Otd.Socgorod 5	2127320	1757428	369892	12	4 438 704	Reprogramming
01136190	Otd.Socgorod 7	153739	0	153739	12	1 844 868	
01136190	Otd.Socgorod 7	1893091	1502655	390436	12	4 685 232	Reprogramming
01136094	Otd.Socgorod 8	140078	0	140078	12	1 680 936	
01136094	Otd.Socgorod 8	1888734	1561883	326851	12	3 922 212	Reprogramming
4848597	Otd.Boks 1	9446	6724	2722	20	54440	
4848599	Otd.Tunnel	14314	10038	4276	1	4276	

b) Power consumption from the grid (Total: 165 045 906 kWh)

01073888	Delivery to plant buses from pr.	114645	0	114645	132	15 133 140	
----------	-------------------------------------	--------	---	--------	-----	------------	--

	LIP 1						
01073888	Delivery to plant buses from pr. LIP 1	463890	158614	305276	132	40 296 432	Reprogramming
01076223	Delivery to plant buses from pr. LIP 2	76406	0	76406	132	10 085 592	
01076223	Delivery to plant buses from pr. LIP 2	433881	118210	315671	132	41 668 572	Reprogramming
	Delivery to plant buses from pr. LIP 2					12 110	Shortage
01083013	Delivery to plant buses from pr. Druzhkovka 1	63490	0	63490	132	8 380 680	
01083013	Delivery to plant buses from pr. Druzhkovka 1	237554	107590	129964	132	17 155 248	Reprogramming
01054389	Delivery to plant buses from pr. Druzhkovka 2	43166	0	43166	132	5 697 912	
01054389	Delivery to plant buses from pr. Druzhkovka 2	260734	64406	196328	132	25 915 296	Reprogramming
	Delivery to plant buses from pr. Druzhkovka 2					7 276	Shortage
01076236	Delivery to plant buses from pr. Kujbisheva 1	0	0	0	88	0	
01082976	Delivery to plant buses from pr. Kujbisheva 1	0	0	0	88	0	Replacement
01076228	Delivery to plant buses from pr. Kujbisheva 2	0	0	0	66	0	
01076228	Delivery to plant buses from pr. Kujbisheva 2	0	0	0	66	0	Reprogramming
01083001	Delivery to plant buses from pr. Kujbisheva 2	65835	65835	0	66	0	Replacement
2821188	Delivery ShSMV			0	1320	0	Maintenance
36118832	Delivery PGV 1 JSC NKMZ	159807	151164	8643	24	207432	
71001641	Delivery PGV 1 JSC NKMZ	176207	155948	20259	24	486216	

Annex 2. Detailed information as to the technical breakdowns during 2010

In 2010 at HPP there were a number of technical breakdowns:

09.02.2010 Boiler # 7 was switched off by the boiler drum level protection system due to the damage of the front waterwall central panel tubes and the rear waterwall tubes caused by internal corrosion.

15.03.2010 Boiler # 9 was switched off by personnel (using KAOT emergency switch) due to sharp level lowering in the boiler drum which resulted from the damage of the front waterwall tube caused by internal corrosion.

19.04.2010 Boiler # 8 was switched off by the boiler drum level protection system due to the damage of the front waterwall tube caused by external corrosion. Turbo generator # 3 was stopped by personnel (using KAOT emergency switch) in connection with no-steam regime.

3.06.2010 Boiler # 8 was switched off by the boiler drum level protection system due to the damage of the rear waterwall tube caused by internal corrosion. Turbo generator # 4 was stopped by personnel (using KAOT emergency switch) in connection with no-steam regime.

21.06.2010 Boiler # 8 was switched off by the boiler drum level protection system due to damage of the front waterwall tube caused by internal corrosion under continuous service. Turbo generator # 4 was stopped by personnel (using KAOT emergency switch) in connection with no-steam regime.

9.08.2010 Boiler #7 was stopped by operating personnel (using KAOK emergency switch) because of leakage in the gland seal of the feed valve. The damage resulted from the valve stem mechanical wear caused by its continuous service. Turbo generator # 3 was stopped by personnel (using KAOT emergency switch) in connection with no-steam regime.

17.08.2010 Turbo generator # 3 was stopped by operating personnel (using KAOT emergency switch) because of turbine condensate pipeline leakage. The damage resulted from continuous service of the pipe stopper. Boiler # 6 was stopped by personnel using KAOK emergency switch.

31.08.2010 Boiler #9 was switched off by the emergency stop protection of two smoke-exhausters due to de-energizing of the switchgear section #9 (6kV) which resulted from short-circuit in the mill exhaust fan 9A section. The short-circuit was caused by break of the protective shutter mount. Turbo generator # 3 was stopped by operating personnel (using KAOT emergency switch) in connection with no-steam regime.

16.10.2010 Boiler # 8 was switched off by the boiler drum level protection system due to the damage of the rear waterwall tube caused by internal corrosion.

3.11.2010 The operating personnel switched off the boiler # 9 (using KAOK emergency switch) in connection with level lowering in the boiler drum caused by the waterwall tube disruption. The damage resulted from internal corrosion. Turbo generator # 4 was stopped by personnel (using KAOT emergency switch) because of steam shortage.

1.12.2010 Boiler # 7 was switched off by personal (using KAOT emergency switch) in connection with sharp level lowering in the boiler drum caused by the front waterwall tube damage which resulted from the tube cracking.

7.12.2010 Boiler # 6 was switched off by the boiler drum level protection system due to the damage of the left side waterwall tube caused by internal corrosion.

8.12.2010 Boiler # 7 was switched off by the boiler drum level protection system due to the damage of the right side waterwall tube caused by internal corrosion.

21.12.2010 Boiler # 6 was switched off by the boiler drum level protection system due to the damage of the front waterwall tube caused by internal corrosion.

27.12.2010 Boiler # 8 was switched off by the boiler drum level protection system due to the damage of the rear waterwall tube caused by internal corrosion.