

# **Monitoring report**

**over period: 01.01.2011 – 30.06.2011**

## **JOINT IMPLEMENTATION PROJECT**

**“Reconstruction of the oxygen compressor plant  
at the JSC “Zaporizhstal”, Ukraine”**

The Project Developer

General Director  
CJSC “National Carbon  
Sequestration Foundation”

\_\_\_\_\_

Fedorov Y.N.

Seal

The Project Owner

Deputy Chairman of Board,  
Technical Director  
JSC “Zaporizhstal”

\_\_\_\_\_

Putnoki A.U.

Seal

**Zaporizhzhya  
September 2011**

## **Contents**

**A. General description of the project and monitoring**

**B. Main activity according to the monitoring plan**

**C. Quality control (QC) and quality assurance (QA) procedures**

**D. Results of GHGs emission reductions monitoring**

**Annex 1. GHGs project emissions calculation**

**Annex 2. GHGs baseline emission calculation**

## Section A. General description of the project and monitoring

### A.1. Title of the project

Reconstruction of the oxygen compressor plant at the JSC “Zaporizhstal”, Ukraine

ITL project ID: UA1000189

Sectoral scope: (3) Energy demand

Date of monitoring report preparation: 08/09/2011

Version: 02.1

### A.2. Short description of the project

JSC “Zaporizhstal” performs the project of oxygen compressor plant (OCP) reconstruction aimed to supply oxygen in required level for pig iron and steel production. Also the project will serve to replace the worn-out air-separation units.

The OCP reconstruction at the JSC “Zaporizhstal” is implemented by the construction of the air-separation unit (ASU) VRU-60, manufactured by Air Liquide (France). The air-separation unit VRU-60 will make it possible to provide production needs with the required amount of oxygen upon achievement following effects:

- reduction of electric power consumption;
- reduction in manufacturing water consumption;
- generation of oxygen without additional compression;
- decrease of oxygen losses during production;
- increase of oxygen concentration up to 99.5%.

The implementation of the project by the construction of VRU-60 will make it possible, versus the situation in the absence of this project (reconstruction of OCP by the construction of a new air-separation units KAAr-32), to significantly reduce the electric power consumption supplied for the OCP operation from the power grid of Ukraine. The reduction in the supply of electric power from the grid will enable electric power generation at the electricity-generating plants of Ukraine to be decreased at the equivalent rate. This will lead to a reduction in the emissions of GHG as a result of the reduction in the consumption of fuel-and-energy resources for electric power.

The operational status of the air separation units installed in the OCP JSC “Zaporizhstal” during the current monitoring period (01/01/2011 – 30/06/2011) are shown below.

№	Air separation unit	Operational status <sup>1</sup>
1.	VRU-60	Operational 01/01/2011 – 30/06/2011
2.	KAr-30	Not operational.
3.	BR-2	Not operational.
4.	KtK-35-3	Not operational. Conservation.

<sup>1</sup> The operational period of each air separation unit is confirmed by technical reports of OCP and by aggregate journals.

### A.3. Stages of the project implementation

№	Stage	Data/period
1.	Construction work	February 2005 – October 2006
2.	Installation work	November 2005 – May 2007
3.	Start and adjusting work	June 2007 – December 2007
4.	Commissioning	27/12/2007

The JI-project “Reconstruction of the oxygen compressor plant at the JSC “Zaporizhstal”, Ukraine” is approved by the Ukraine (Host party)<sup>2</sup> and by the Switzerland<sup>3</sup>. The Letters of Approval are attached to the monitoring report.

### A.4. Deviations and corrections of approved PDD

Absent.

### A.5. Monitoring period

Date of the start of monitoring: 01/01/2011

Date of the end of monitoring: 30/06/2011

### A.6. Monitoring results for the current period

Period of monitoring	Project emissions (tCO <sub>2</sub> -eq.)	Leakages (tCO <sub>2</sub> -eq.)	Baseline emissions (tCO <sub>2</sub> -eq.)	Emission reductions (tCO <sub>2</sub> -eq.)
01/01/2011 - 30/06/2011	259,299	-	293,018	33,719

The GHG emission reductions achieved during the current monitoring period (33,719 tCO<sub>2</sub>-eq.) are less than estimated value for the corresponding period (54,285 tCO<sub>2</sub>-eq.) because of increase of actual values of oxygen production and distribution in the OCP JSC “Zaporizhstal” in comparison to the forecasted data used for GHG emission reductions estimation. The detailed information is provided in the section D.5 of the monitoring report “Results of GHGs emission reductions monitoring”.

### A.7. Methodology used for monitoring of GHGs emission reductions

Baseline of the project is determined in accordance with “Combined tool to identify the baseline scenario and demonstrate additionality (Version 02.1)”. For the baseline setting were used JI Guidelines, Baseline setting and monitoring (Version 01), and also with generic approach of

---

<sup>2</sup> Letter of Approval from National Environmental Investment Agency of Ukraine ref. No 1514/23/7, issued on 14/12/2009

<sup>3</sup> Letter of Approval for a project under article 6 of the Kyoto Protocol (JI) of the Federal Office for the Environment (FOEN) of Switzerland ref. No J294-0485, issued on 23/07/2010

“Tool to calculate baseline, project and/or leakage emissions from electricity consumption (Version 01)”.

Monitoring of GHGs was done in accordance with the developed monitoring plan of project design documentation (section D). Monitoring plan was developed in accordance with JI Guidelines, Baseline setting and monitoring (Version 01), and also with generic approach of “Tool to calculate baseline, project and/or leakage emissions from electricity consumption (Version 01)”.

## **A.8. Deviations and corrections of approved monitoring plan**

### **Deviations and corrections of approved monitoring plan in the current monitoring period**

The value of CO<sub>2</sub> emission factor during electric power generation supplied by the power system of Ukraine ( $EF_{CO_2,ELEC,y}$ ) is revised according to the Order #75 of National Environmental Investment Agency of Ukraine dated on 12/05/2011. The electricity consumers in OCP JSC “Zaporizhstal” corresponds to the two class of electricity consumers stated in the Order #1052 of National committee of electric energy regulation in Ukraine dated on 13/08/1998:

- the first class of electricity consumers (about 92-96% of electricity consumed in OCP from substation M1 – received electricity from the grid with voltage 150 kV (more than 27.5 kV in the point of electricity sale);
- the second class of electricity consumers (about 4-8% of electricity consumed in OCP from substation M3 – received electricity from the grid with voltage 6 kV (less than 27.5 kV in the point of electricity sale).

Therefore the revised value of CO<sub>2</sub> emission factor during electric power generation supplied by the power system of Ukraine ( $EF_{CO_2,ELEC,y}$ ) is determined for monitoring in 2011 in rate of 1.090 tCO<sub>2</sub>/MWh corresponding to the first class of electricity consumers. The choice of the emission value is based on conservative approach as the emission factor for second class of electricity consumers is more than for the first class.

The value of the parameter ( $EF_{CO_2,ELEC,y}$ ) will be revised in 2012 based on corresponding recommendation of National Environmental Investment Agency of Ukraine.

### **Justification of deviations and corrections of approved monitoring plan**

The revision of CO<sub>2</sub> emission factor during the electric power generation supplied by the power grid is in accordance with regulations of National Environmental Investment Agency of Ukraine for improvement of common approach of GHG emission reductions estimation in JI projects.

### **Deviations and corrections of approved monitoring plan verified in the previous period**

Deviations and corrections of approved monitoring plan are provided for monitoring quality assurance and transparency of GHG monitoring and stated in the Revised monitoring plan version 01 dated on 15/09/2010, Monitoring report for 2008 dated on 27/11/2009, Monitoring report for 2009 dated on 14/04/2010. Deviations and corrections cover the following positions of approved monitoring plan:

- Uncertainty level and verification frequency of meters are specified;
- Operational and management structure of monitoring is corrected;
- Monitoring of electricity consumption for production in OCP since 01/01/2009 are provided daily (not monthly how determined in PDD). This is possible because of commissioning of electronic system for technical registration of electricity consumption at the JSC “Zaporizhstal”. Daily electricity consumption monitoring ensures continuous and transparent data;

- The barometric pressure data for oxygen generation/distribution monitoring are taken from the JSC “Zaporizhgas”. The procedures of barometric pressure data collection, using and archiving are determined by Manual of planimetrist. The data of barometric pressure taken from the independent organization ensures the quality of data used and results of emissions calculation;
- The length of the crediting period is corrected: 01/01/2008 – 31/12/2012 (5 years, 60 months);
- The calculation of baseline emissions is specified: In case the oxygen production in the baseline scenario ( $P_{\text{oxygen, BL, y}}$ ) calculated on the conservative provisions of the monitoring plan will be less than the measured oxygen production in the project scenario than the oxygen production in the baseline will be equal to the oxygen production in the project scenario. This is a conservative assumption as that provides to the zero emission reductions.

All the above deviations and corrections of approved monitoring plan are verified.<sup>4</sup>

The List of parameters that are monitored throughout the crediting period stated in the Monitoring report for current monitoring period (section B.1.2) was completed with parameter  $N_{\text{day, j}}$  (Number of days then the OCP was operated in operating conditions j). In the previous monitoring period (2008-2009) this parameter ( $N_{\text{day, j}}$ ) was used for calculation of baseline emissions (according to the formulas D.2, D.2.1-2.4 of the monitoring plan) but was not stated in the List of monitored parameters. The monitoring procedures including QA/QC procedures were not changed.

#### **A.9. Person(s) responsible for the preparation and submission of the monitoring report**

JSC “Zaporizhstal”

Contact person: Ms. Inna Holina, Head of Laboratory of environment protection

Tel.: +38 061 218 24 07

Fax: +38 061 218 24 07

E-mail: holina@zaporizhstal.com

CJSC “National Carbon Sequestration Foundation”

Contact person: Mr. Roman Kazakov, Principal Specialist of Department of GHG Emissions Management

Tel.: +7 499 788 78 35 ext. 113

Fax: +7 499 788 78 35 ext. 107

E-mail: KazakovRA@ncsf.ru

---

<sup>4</sup> Source: <http://www.carbonunitsregistry.gov.ua/en/publication/content/795.htm>

## Section B. Main activity according to the monitoring plan

### B.1. Initial data for monitoring

#### B.1.1. List of fixed parameters for all monitoring period

№	Data variable	Description	Data unit	Source of data	Comment
1.	$EF_{CO_2,ELEC,y}$	Emission factor during electric power generation supplied by the power system of Ukraine	tCO <sub>2</sub> /MWh	Order #75 of National Environmental Investment Agency of Ukraine dated on 12/05/2011	$EF_{CO_2,ELEC,y} = 1.090$ tCO <sub>2</sub> /MWh
2.	$SP_{oxygen,BL,j}$	Output of the air-separation units (KAAR-32) in operating conditions j	m <sup>3</sup> /hour	Project documentation for KAAR-32	$SP_{oxygen,BL,j} = 60,000$ m <sup>3</sup> /hour, 62,000 m <sup>3</sup> /hour, 64,000 m <sup>3</sup> /hour. Output of the air-separation units depends on distributed oxygen ( $D_{oxygen,PJ,day}$ ) and are to be determined based on table B.1-1. of the monitoring report or table D.1-1. of the PDD

#### B.1.2. List of parameters that are monitored throughout the crediting period

№	Data variable	Description	Data unit	Source of data	Comment
1.	ID-1, $EC_{OCP,PJ,y}$	Electric power consumption by the OCP	MWh	Electric power meter	To be registered by the plant of networks and substations
2.	ID-2, $P_{oxygen,VRU-60,y}$	Oxygen production in the air-separation unit VRU-60	thousand m <sup>3</sup>	Flow-rate meter	To be registered by the Chief Power Engineer Department


№	Data variable	Description	Data unit	Source of data	Comment
3.	ID-3, $P_{\text{oxygen,RASU,y}}$	Oxygen production in the reserved air-separation units	thousand $\text{m}^3$	Flow-rate meter	To be registered by the Chief Power Engineer Department
4.	ID-4, $D_{\text{oxygen,PJ,day}}$	Distributed oxygen	thousand $\text{m}^3$	Flow-rate meter	To be registered by the Chief Power Engineer Department
5.	$N_{\text{day,j}}$	Number of days then the OCP was operated in operating conditions j	day	Estimated	Determined based on actual data of distributed oxygen ID-4 ( $D_{\text{oxygen,PJ,day}}$ ) according to the table B.1-1. of the monitoring report or table D.1-1. of the PDD

### B.1.3. Scheme of monitoring points

The monitoring points of GHGs emissions are shown in the following figure B.1-1.



Fig. B.1-1. Scheme of monitoring points location.



	Electric power
	Fuel-and-power resources (TPR)
	Oxygen
	Oxygen losses
	Technical water
	Air
	Boundary of the JSC "Zaporizhstal"
	Project boundary

Monitoring points	Description
ID-1	Electric power consumption by the OCP
ID-2	Oxygen production in the air-separation unit VRU-60
ID-3	Oxygen production in the reserved air-separation units
ID-4	Distributed oxygen

## B.1.4. Formulas used in monitoring plan

### B.1.4.1. Formulas used to calculate project emissions

$$(D.1) \quad PE_{EC,y} = EC_{OCP,PJ,y} * EF_{CO2,ELEC,y}$$

$PE_{EC,y}$  - project emissions, tCO<sub>2</sub>

$EC_{OCP,PJ,y}$  - electric power consumption by the OCP due to the project activity, MWh

$EF_{CO2,ELEC,y}$  - emission factor during electric power generation supplied by the power system of Ukraine, tCO<sub>2</sub>/MWh

### B.1.4.2. Formulas used to calculate baseline emissions

$$(D.2) \quad BE_{EC,y} = EC_{OCP,BL,y} * EF_{CO2,ELEC,y}$$

$BE_{EC,y}$  - baseline emissions, tCO<sub>2</sub>

$EC_{OCP,BL,y}$  - electric power consumption by the OCP according to the baseline, MWh

$EF_{CO2,ELEC,y}$  - emission factor during electric power generation supplied by the power system of Ukraine, tCO<sub>2</sub>/MWh

The electric power consumption by the OCP for oxygen production is calculated by the formula:

$$(D.2.1) \quad EC_{OCP,BL,y} = P_{oxygen,BL,y} * SEC_{oxygen,BL}$$

$P_{oxygen,BL,y}$  - total oxygen production according to the baseline, thousand m<sup>3</sup>

$SEC_{oxygen, BL}$  - specific electric power consumption for production in the OCP according to the baseline, MWh/thousand m<sup>3</sup>(O<sub>2</sub>)

The total oxygen production according to the baseline is calculated by the formula:

$$(D.2.2) \quad P_{oxygen,BL,y} = \sum (SP_{oxygen,BL,j} * T_{OCP,j}) + P_{oxygen,RASU,y}$$

$SP_{oxygen,BL,j}$  - output of the air-separation units (KAAR-32) according to the baseline in operating conditions j, thousand m<sup>3</sup>(O<sub>2</sub>)/hour

$T_{OCP,j}$  - operational time for the air-separation units in operating conditions j, hours

$P_{oxygen,RASU,y}$  - oxygen production output in the reserved air-separation units, thousand m<sup>3</sup>(O<sub>2</sub>)

In baseline scenario are considered the following equipment in the OCP: two units KAAR-32 and reserved units (KAR-30, KtK-35-3 and BR-2). The total oxygen production in the baseline scenario includes the oxygen production in the ASUs KAAR-32 and in the reserved units. The oxygen production in baseline depends on the needs of oxygen in the steel plant (distributed oxygen). On the bases of distributed oxygen in project scenario (ID-4 – direct monitored) can be supposed how would be operated the equipment in the OCP – the operating conditions (j) (table D.1-1 of the PDD, table B.1-1). The data of specific oxygen production in units KAAR-32 ( $SP_{oxygen,BL}$ ) and oxygen production in reserved ASUs ( $P_{oxygen,RASU,y}$ ) are determined as optimal work of equipment for appropriate distributed oxygen (table D.1-1 of the PDD, table B.1-1).

The operational time for the air-separation units ( $T_{OCP,y}$ ) in operating conditions (j) is calculated by the formula:

$$(D.2.3) \quad T_{OCP,j} = N_{day,j} * 24$$

$N_{day,j}$  - number of days then the OCP was operated in operating conditions j (table B.1-1), day

24 - hours per day, hour

The number of days then the OCP was operated in operating conditions j is to be determined based on actual data of distributed oxygen ( $D_{oxygen,PJ,day}$ ) – ID-4.

The specific electric power consumption for production in the OCP according to the baseline ( $SEC_{oxygen,BL}$ ) is calculated by the formula:

$$(D.2.4) \quad SEC_{oxygen,BL} = EC_{OCP,PJ,y} / (P_{oxygen,VRU-60,y} + P_{oxygen,RASU,y})$$

$EC_{OCP,PJ,y}$  - electric power consumption by the OCP due to the Project activity, MWh

$P_{oxygen,VRU-60,y}$  - oxygen production output in the air-separation unit VRU-60, thousand  $m^3(O_2)$

$P_{oxygen,RASU,y}$  - oxygen production output in the reserved air-separation units, thousand  $m^3(O_2)$

The electric power consumption by the OCP ( $EC_{OCP,PJ,y}$ ), oxygen production output in the air-separation unit VRU-60 ( $P_{oxygen,VRU-60,y}$ ) and oxygen production output in the reserved air-separation units  $P_{oxygen,RASU,y}$  will be measured directly (monitoring points: ID-1, ID-2, ID-3).

Table B.1-1. The operation of the oxygen compressor plant in the baseline scenario.

Operating conditions (j)	Distributed oxygen ( $D_{oxygen,PJ,day}$ ), $m^3(O_2)/day$	Number and type of ASUs <sup>5</sup>	Specific oxygen production in ASUs KAAr-32 ( $SP_{oxygen,BL}$ ), $m^3(O_2)/hour$	Oxygen production in reserved ASUs ( $P_{oxygen,RASU,y}$ ), $m^3(O_2)/hour$
1.	$D_{oxygen,PJ,day} < 1,368,000$	2 x KAAr-32	60,000	0
2.	1,368,000 – 1,413,600	2 x KAAr-32	62,000	0
3.	1,413,600 – 1,459,200	2 x KAAr-32	64,000	0
4.	$D_{oxygen,PJ,day} > 1,459,200$	2 x KAAr-32, reserved units (KAr-30 and/or BR-2)	60,000	Direct monitored (ID-4)

#### B.1.4.3. Formulas used to calculate emission reductions

$$(D.3.) \quad ER_{EC,y} = BE_{EC,y} - PE_{EC,y}$$

$ER_{EC,y}$  - emission reductions, tCO<sub>2</sub>

$BE_{EC,y}$  - baseline emissions, tCO<sub>2</sub>

$PE_{EC,y}$  - project emissions, tCO<sub>2</sub>

<sup>5</sup> ASU – Air separation unit.

## **B.2. Procedures and scheme of monitoring**

The procedures of GHGs emission reductions monitoring are determined by the Company standard STP 8.2-13-10 “Integrated quality system. Monitoring of GHGs emission reductions”, approved by Order #98 of JSC “Zaporizhstal” dated on 05/03/2010.

In monitoring of GHGs emission reductions by the project “Reconstruction of the oxygen compressor plant” participate following departments of JSC “Zaporizhstal”:

- Laboratory of environment protection;
- Power bureau of Chief Power Engineer Department;
- Recording bureau of Chief Power Engineer department;
- Technical bureau of Plant of networks and substations;
- Technical bureau of Oxygen compressor plant.

By the monitoring plan the following parameters will be monitored in accordance with monitoring plan:

- Electricity consumption by the OCP;
- Oxygen production in VRU-60;
- Oxygen production in reserved units (KAr-30, KtK-35-3, BR-2);
- Distributed oxygen.

Scheme of collecting and carrying of monitoring data for GHGs emission reductions are shown on the fig. B.2-1. Units of company included in the monitoring of GHGs emissions, responsible specialists and their functions are shown in table B.2-1.

Fig. B.2-1. Scheme of collecting and carrying of monitoring data.




Table B.2-1. Departments of the company participating in GHGs emission monitoring, responsible specialists and their functions.

№	Title of the department	Responsible specialists	Monitoring functions	Frequency
1	Technical bureau of Plant of networks and substations	Head	Preparation of monthly reports of electricity consumption for production in OCP (ID-1, $EC_{OCP, PJ, y}$ ) based on reading of electricity meters at the beginning of month and the end of a month received from the system of technical monitoring of electricity consumption.	Monthly
			Control and confirmation of monthly reports of electricity consumption for production in OCP based on logs of daily registration electricity consumption on substation of Plant of networks and substations.	Monthly
			Delivery of controlled and confirmed monthly reports of electricity consumption for production in OCP to Power bureau of Chief Power Engineer Department.	Monthly
			Storage of monthly reports of electricity consumption for production in OCP and reading of electricity meters at the beginning of month and the end of a month received from the system of technical monitoring of electricity consumption on the paper and electronic files. Storage of logs of daily registration electricity consumption on substation of Plant of networks and substations on the paper files.	During the crediting period and for two years after the last operation with ERUs

№	Title of the department	Responsible specialists	Monitoring functions	Frequency
2	Recording bureau of Chief Power Engineer department	Engineer	Preparation of monthly reports of oxygen production in VRU-60 (ID-2, $P_{\text{oxygen,VRU-60,y}}$ ), in reserved units (ID-3, $P_{\text{oxygen,RASU,y}}$ ), distributed oxygen (ID-4, $D_{\text{oxygen,PJ,day}}$ ) based on primary recording data, prepared daily by Recording bureau of Chief Power Engineer department based on measured data of flow meters in oxygen-compressor plant.	Monthly
			Primary data of oxygen production in VRU-60 (ID-2, $P_{\text{oxygen,VRU-60,y}}$ ) are supplied by operator of VRU-60 to Recording bureau of Chief Power Engineer department in Form of energy recourses production and consumption in VRU-60.	
			Primary data of oxygen production in reserved units (ID-3, $P_{\text{oxygen,RASU,y}}$ ) and distributed oxygen (ID-4, $D_{\text{oxygen,PJ,day}}$ ) are supplied by Control equipment and automatization department of the oxygen compressor plant to Recording bureau of Chief Power Engineer department in diagrams.	
			Delivery of monthly reports of oxygen production in VRU-60, in reserved units, distributed oxygen to Head of Technical bureau of Oxygen compressor plant for control and confirmation.	Monthly
			Storage of primary recording data of oxygen production in VRU-60, in reserved units, distributed oxygen on the paper and electronic files.	During the crediting period and for two years after the last operation with ERUs
3	Technical bureau of Oxygen compressor plant	Head	Control and confirmation of monthly reports of oxygen production in VRU-60, in reserved units, distributed oxygen based on manufacturing reports of oxygen compressor plant.	Monthly

№	Title of the department	Responsible specialists	Monitoring functions	Frequency
			Delivery of controlled and confirmed monthly reports of oxygen production in VRU-60, in reserved units, distributed oxygen to Power bureau of Chief Power Engineer Department.	Monthly
			Storage of manufacturing reports of oxygen compressor plant on the paper and electronic files. Storage of monthly reports of oxygen production in VRU-60, in reserved units, distributed oxygen on the paper files.	During the crediting period and for two years after the last operation with ERUs
4	Power bureau of Chief Power Engineer Department	Power Engineer	Collection of monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen. Preparation of summary monthly reports.	Monthly
			Delivery of summary monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen to Deputy Chief Power Engineer for approval.	Monthly
			Delivery of by Deputy Chief Power Engineer approved summary monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen to Laboratory of environment protection.	Monthly
			Storage of summary monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen on the paper and electronic files.	During the crediting period and for two years after the last operation with ERUs
5	Chief Power Engineer Department	Deputy Chief Power Engineer	Approval of summary monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen.	Monthly



№	Title of the department	Responsible specialists	Monitoring functions	Frequency
6	Laboratory of environment protection	Head	Collection of by Deputy Chief Power Engineer approved summary monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen.	Monthly
			Calculation of GHGs emission reductions according to the formulas of monitoring plan based on data of by Deputy Chief Power Engineer approved summary monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen.	Monthly
			Storage of summary monthly reports of electricity consumption for production in OCP, oxygen production in VRU-60, in reserved units, distributed oxygen and results of GHGs emission reductions monitoring on the paper and electronic files. Storage of GHGs emission reductions calculations on electronic files.	During the crediting period and for two years after the last operation with ERUs

### **B.3. Meters included in the monitoring plan**

For the recording of monitoring parameters are used following meters:

- Electricity meters – metering of electricity consumption for production in OCP;
- Flow-rate meters – metering of oxygen production and distribution.

#### **B.3.1. Information of used meters**

The information of used meters including data about their types, functions, calibration's and verification's data are provided in the attached meters certificates and in the tables B.3.1-1 - B.3.1-3.

The information of measuring devices calibration and verification stated in the tables B.3.1-1 - B.3.1-2 is completed with information about meters installation and replacement dates according to the FAR 01 of Verification report Bureau Veritas Certification for the previous monitoring period No. UKRAINE-ver/0205/2010 dated on 10/03/2011.

Table B.3.1-1. The meters for electricity consumption<sup>6</sup>

№	Location of meters: Substation, connection	Type of meters <sup>7</sup>	№ of meters	Date of installation	Date of last verification	Date of current verification	Date of next verification
1.	M1: 55-1/12	EA05RL-B-4	01103338	18.10.2010	21.08.2010	-	21.08.2016
2.	M1: 55-2/63	EA05RL-B-4	01103311	18.10.2010	21.08.2010	-	21.08.2016
3.	M : 55-3/48	EA05RL-B-4	01103220	18.10.2010	15.09.2010	-	15.09.2016
4.	M1: 55-4/62	EA05RL-B-4	01103321	18.10.2010	15.09.2010	-	15.09.2016
5.	M1: СД-1/1	EA05RALX-B-4	01050771	08.12.2010	09.11.2010	-	09.11.2016
6.	M1: СД-2/40	EA05RALX-B-4	01059590	11.11.2010	23.09.2010	-	23.09.2016
7.	M1: СД-6/16	EA05RALX-B-4	01050778	17.01.2011	02.11.2010	-	02.11.2016
8.	M1: СД-17/58	EA05RALX-B-4	01059584	11.11.2010	02.11.2010	-	02.11.2016
9.	ПС-10: КТП- ККЦ/6к	EA05RL-B-4	01103223	21.10.2010	15.09.2010	-	15.09.2016
10.	M3: 55-5/3	EA05RL-B-4	01103231	20.10.2010	15.09.2010	-	15.09.2016
11.	M3: 355-1/21	EA05RL-B-4	01103339	20.10.2010	15.09.2010	-	15.09.2016
12.	M3: 355-2/30	EA05RL-B-4	01103288	20.10.2010	15.09.2010	-	15.09.2016
13.	M3: СД-26/9	EA05RALX-B-4	01089275	12.11.2010	23.09.2010	-	23.09.2016

<sup>6</sup> The provided data are compiled based on meters certificates and verification/calibration certificates. The attached documents confirm the quality and accuracy of the monitoring parameters recording through the monitoring period.

<sup>7</sup> Type of meters: microprocessor electronic meters - "Euro-Alpha"

№	Location of meters: Substation, connection	Type of meters <sup>7</sup>	№ of meters	Date of installation	Date of last verification	Date of current verification	Date of next verification
14.	M3:СД-21/27	EA05RALX-B-4	01126401	29.12.2005	28.09.2005	-	28.09.2011
15.	M3: СД-29/29	EA05RALX-B-4	01126395	29.12.2005	28.09.2005	-	28.09.2011
16.	M3: СД-20/12	EA05RALX-B-4	01059589	12.11.2010	24.11.2009	-	24.11.2015
17.	M3: СД-23/14	EA05RALX-B-4	01126402	29.12.2005	28.09.2005	-	28.09.2011
18.	M3:СД-27/18	EA05RALX-B-4	01103398	12.11.2010	02.11.2010	-	02.11.2016
19.	M3: СД-28/20	EA05RALX-B-4	01144050	07.12.2010	06.09.2006	-	06.09.2012
20.	M3:СД-30/28	EA05RALX-B-4	01126399	30.12.2005	28.09.2005	-	28.09.2011
21.	M3: СД-32/45	EA05RALX-B-4	01126397	30.12.2005	28.09.2005	-	28.09.2011
22.	M3:СД-31/47	EA05RALX-B-4	01050775	12.11.2010	01.07.2010	-	01.07.2016
23.	M3: СД-33/49	EA05RALX-B-4	01059594	25.11.2009	24.11.2009	-	24.11.2015
24.	M3: СД-34/51	EA05RALX-B-4	01050766	25.11.2009	24.11.2009	-	24.11.2015
25.	M3:СД-22/42	EA05RALX-B-4	01089278	12.11.2010	23.09.2010	-	23.09.2016
26.	M3:СД-35/46	EA05RALX-B-4	01059531	25.11.2009	24.11.2009	-	24.11.2015
27.	M3:СД-36/48	EA05RALX-B-4	01059555	12.11.2010	23.09.2010	-	23.09.2016
28.	M3: АД-1/19	EA05RALX-B-4	01059569	12.11.2010	23.09.2010	-	23.09.2016

Table B.3.1-2. Flow-rate meters for oxygen production in air-separation units and oxygen distribution

№	Location of meters	Type of meters	№ of meters	Date of installation	Date of last verification	Date of current verification	Date of next verification
A. Meters for oxygen production in VRU-60							
1.	Oxygen Compressor Plant	Primary sensor: Rosemount 3051-CD Second meter: Controller ACS VRU <sup>8</sup>	8066805	2008	11.08.2010	11.08.2011	11.08.2012
2.	Oxygen Compressor Plant	Primary sensor: Rosemount 3051-CD Second meter: Controller ACS VRU	8066806	2008	11.08.2010	11.08.2011	11.08.2012
B. Meters for oxygen production in KtK-35-3 <sup>9</sup>							
3.	Oxygen Compressor Plant	Primary sensor: ДМ-3583	12215	2006	08.04.2009	Preservation	-
		Second meter: ВФС	3539	2006	08.04.2009	Preservation	-
		Second meter: КСФ-3	18	2006	14.05.2009	Preservation	-
4.	Oxygen Compressor Plant	Primary sensor: ДМ-3583	5690	2006	08.04.2009	Preservation	-
		Second meter: ВФС	15506	2006	08.04.2009	Preservation	-
		Second meter: КСФ-3	1119	2006	14.05.2009	Preservation	-
C. Meters for oxygen production in KAr-30							
5.	Oxygen Compressor Plant	Primary sensor: ДМ-3583	14294	2008	14.04.2010	14.04.2011	14.04.2012
		Second meter: КСД-250	73535	2008	14.04.2010	14.04.2011	14.04.2012
		Second meter: ДИСК-250	53356	2008	13.05.2010	13.05.2011	13.05.2012
D. Meters for oxygen production in BR-2							
6.	Oxygen Compressor Plant	Primary sensor: ДМ-3583	2913	2006	14.04.2010	14.04.2011	14.04.2012
		Second meter: КСД-250	68584	2006	14.04.2010	14.04.2011	14.04.2012
		Second meter: ДИСК-250	53355	2006	13.05.2010	13.05.2011	13.05.2012

<sup>8</sup> There is a duplication second meter for oxygen production recording in VRU-60: СИП-762 #1355 (the verification data are provided in the row 8. of this table).

<sup>9</sup> The air separation unit KtK-35-3 was put into preservation 05.01.2008 (confirmed by Aggregate journal of KtK-35-3)

№	Location of meters	Type of meters	№ of meters	Date of installation	Date of last verification	Date of current verification	Date of next verification
7.	Oxygen Compressor Plant	Primary sensor: ДМ-3583	58848	2006	14.04.2010	14.04.2011	14.04.2012
		Second meter: КСД-250	68583	2006	14.04.2010	14.04.2011	14.04.2012
		Second meter: ДИСК-250	53353	2006	26.05.2010	13.05.2011	13.05.2012
E. Meters for oxygen distribution							
8.	Oxygen Compressor Plant (input in Open-hearth plant №1)	Primary sensor: Сафир-М Second meter: СПГ-762	11802921 1355	2007 2007	26.05.2010 25.11.2010	13.05.2011 -	13.05.2012 25.11.2014
9.	Oxygen Compressor Plant (input in Open-hearth plant №2)	Primary sensor: ДМ-3583 Second meter: КСД-3	61341 202713	2006 2006	13.05.2010 13.05.2010	13.05.2011 13.05.2011	13.05.2012 13.05.2012
10.	Oxygen Compressor Plant (input in Open-hearth plant №3)	Primary sensor: ДМ-3583 Second meter: КСД-3	41087 104941	2005 2005	13.05.2010 13.05.2010	13.05.2011 13.05.2011	13.05.2012 13.05.2012
11.	Oxygen Compressor Plant (input in Dneprospestal)	Primary sensor: ДМ-3583 Second meter: КСД-3	40445 118805	2006 2006	13.05.2010 13.05.2010	13.05.2011 13.05.2011	13.05.2012 13.05.2012
12.	Oxygen Compressor Plant (input in autogenous plant – west side)	Primary sensor: ДМ-3583 Second meter: КСД-3	481 250891	2005 2005	14.05.2010 14.05.2010	13.05.2011 13.05.2011	13.05.2012 13.05.2012
13.	Oxygen Compressor Plant (input in autogenous plant – east side)	Primary sensor: ДМ-3583 Second meter: КСД-3	24020 59498	2006 2006	13.05.2010 13.05.2010	13.05.2011 13.05.2011	13.05.2012 13.05.2012
14.	Oxygen Compressor Plant (input in heat and power plant)	Primary sensor: АРГ 31.2 Second meter: ДИСК-250	171 1511	2008 2008	28.12.2009 13.05.2010	28.12.2011 13.05.2011	28.12.2013 13.05.2012

Table B.3.1-3. Uncertainty level of meters

№	Type of meters	Uncertainty level
1.	Euro-Alpha	$\pm (0,5-1,0)\%$
2.	Rosemount	$\pm 0,075\%$
3.	ДМ-3583	$\pm 1,5\%$
4.	ВФС	$\pm 1,0\%$
5.	КСФ-3	$\pm 1,0\%$
6.	КСД-250	$\pm 1,0\%$
7.	ДИСК-250	$\pm 1,0\%$
8.	Сафир-М	$\pm 0,5\%$
9.	СПГ-762	$\pm 0,05\%$
10.	КСД-3	$\pm 1,0\%$
11.	АРГ 31.2	$\pm 1,0\%$

### B.3.2. Procedures of verification

Automation and metrological department of JSC “Zaporizhstal” is responsibility for organization of monitoring meters verification. Verification of meters are provided by State enterprise “Zaporizhzhya Scientific production center of standardization, metrology and certification”.

Table B.3.2-1. Frequency of meters verification

№	Type of meters	Verification frequency
1.	Euro-Alpha	once every 6 years
2.	Rosemount	once a year
3.	ДМ-3583М	once a year
4.	ВФС	once a year
5.	КСФ-3	once a year
6.	КСД-250	once a year
7.	ДИСК-250	once a year
8.	Сафир-М	once a year
9.	СПГ-762	once every 2 years <sup>10</sup>
10.	КСД-3	once a year
11.	АРГ 31.2	once every 2 years

<sup>10</sup> Verification frequency determined by Ukrainian Register of SIT is once every 2 years. Verification frequency determined by meters producer is once every 4 years. Calibration frequency is once a year. Since 2010 the verification of СПГ-762 is provided once every 2 years and calibration - once a year.

#### **B.4. Monitoring of project's impact on the environment**

Not applicable. Project activity doesn't have considerable impact on the environment (see section F of the PDD).

#### **B.5. Information of special equipment regimes exploitation**

The special equipment regimes exploitation includes the situations when the main project equipment and measuring devices are exploited in nonstandard conditions because of defects, trouble, malfunction, etc. The special equipment regimes can potential affect the change of monitoring parameters and as a result the GHG emissions reduction monitoring.

The troubleshooting procedures for main project equipment and measuring devices are clearly described in the section C.3.

During the current monitoring period (01/01/2011-30/06/2011) the special equipment regimes exploitation are not appeared.

#### **B.6. Processing and storage of information**

All necessary information for monitoring of GHGs emission reductions are stored in paper and electronic files and will be saved till the crediting period and for two years after the last operation with ERUs from the project. The procedures of monitoring data archiving and responsible person are determined by STP 8.2-13-10 "Monitoring of GHG emission reductions" and other internal documents. The description of data processing and storage is described in the section B.2. of the monitoring report.



## **Section C. Quality control (QC) and quality assurance (QA) procedures**

### **C.1. Internal audit and checking measures**

Quality control of monitoring of GHGs emission reductions is a part of system of regular measures in order to make data more complete and right and to avoid mistakes in documentation and achieving of data.

The QA/QC procedures are determined by Standard JSC “Zaporizhstal” STP 8.2-13-10 “Monitoring of GHG emission reductions” and other internal documents. The QA/QC procedures include:

- quality assurance of the measured monitoring parameters;
- quality assurance of monitoring data processing and recording;
- quality assurance of monitoring data archiving;
- quality control of internal documentation, archiving data, calculation correctness.

The QA/QC procedures including information about responsible department/person, frequency and reporting documentation are detailed described in the section B.2. of the monitoring report.

Quality of the GHG emission reductions monitoring is also ensured by internal audit procedures specified in area of STP 8.2-13-10 “Monitoring of GHG emission reductions” by Direction JSC “Zaporizhstal” #349 dated on 01/09/2010. Technical department is responsible for internal audit. The results of internal audits provided during monitoring period are presented in the protocols of internal audits.

### **C.2. Participation of third parties**

Verification of meters are provided by State enterprise “Zaporizhzhya’ Scientific production center of standardization, metrology and certification”.

### **C.3. Procedures of emergencies finding**

The procedures of emergencies finding (troubleshooting) include the procedures of identification, registration and elimination of defects, trouble, malfunction, etc. in the main project equipment and measuring devices.

#### The procedures of troubleshooting for main project equipment:

The procedures (incl. responsibility, frequency, etc.) of troubleshooting for main equipment are determined by Instructions of equipment exploitation and Job instructions. The specialists of OCP provide periodically the inspection of main and auxiliary equipment of air separation units in OCP. The information of discovered defects is recorded in aggregates journal.

#### The procedures of troubleshooting for measuring devices:

The procedures (incl. responsibility, frequency, etc.) of troubleshooting for measuring devices are determined by STP 7.6-01-03 “Measurement assurance. General provisions.”, STP 7.6-07-03 “Organization and order of meters calibration and verification”, Job instructions of CHPP and Department control equipment and automation.

The staff of Department of control equipment and automation provides periodically the inspection and maintenance of measuring devices. The information about defects, trouble (and provided calibration/verification) is recorded in meters certificates. In case of meters breakdown the measuring devices are to be replaced by reserved devices. In case of malfunction of

registration devices the processing of measured data is provided in accordance with Instruction of planemetrists.

During the current monitoring period (01/01/2011-30/06/2011) the special equipment regimes exploitation is not appeared.

## **Section D. Results of GHGs emission reductions monitoring**

### **D.1. GHGs project emissions**

Calculation of GHGs project emissions is shown in the Annex 1. Results of project emissions monitoring for the period (01/01/2011-30/06/2011) are shown below.

Table D.1-1. GHG emissions in project scenario in 2011

<b>№</b>	<b>Month</b>	<b>Value, t CO<sub>2</sub>-eq.</b>
1.	January	43,593
2.	February	41,051
3.	March	44,097
4.	April	43,777
5.	May	44,395
6.	June	42,386
7.	Total	259,299

### **D.2. GHGs baseline emissions**

Calculation of GHGs by the baseline is shown in the Annex 2. Results of baseline emissions for the period (01/01/2011-30/06/2011) are shown below.

Table D.2-1. GHG emissions in baseline scenario in 2011

<b>№</b>	<b>Month</b>	<b>Value, t CO<sub>2</sub>-eq.</b>
1.	January	50,697
2.	February	47,843
3.	March	50,285
4.	April	45,823
5.	May	49,824
6.	June	48,546
7.	Total	293,018

### **D.3. Leakages**

Not applicable.

#### D.4. Calculation of GHGs emission reductions

Table D.4-1. Calculation of GHGs emission reductions in 2011

№	Month	Project emissions (tCO <sub>2</sub> -eq.)	Leakages (tCO <sub>2</sub> -eq.)	Baseline emissions (tCO <sub>2</sub> -eq.)	Emission reductions (tCO <sub>2</sub> -eq.)
1.	January	43,593	-	50,697	7,104
2.	February	41,051	-	47,843	6,792
3.	March	44,097	-	50,285	6,188
4.	April	43,777	-	45,823	2,046
5.	May	44,395	-	49,824	5,429
6.	June	42,386	-	48,546	6,160
7.	Total	259,299	-	293,018	33,719

#### D.5. Deviations of actual emission reductions from emission reductions estimated in PDD

Table D.5-1. Deviations of actual emission reductions in 2011 from estimated emission reductions

№	Parameter	Emission reductions (tCO <sub>2</sub> -eq.)
1.	Estimated data <sup>11</sup>	54,285
2.	Actual data	33,719
3.	Deviations <sup>12</sup>	-20,566

Deviations of actual emission reductions from estimated in period January - June 2011 can be in general explained by increase of oxygen production losses in the current period on 5% in comparison to estimated value and by increase of oxygen distribution on 7% in comparison to estimated value.

<sup>11</sup> The provided estimated data is calculated as 50% from the estimated value for 2011. (Source: Revision of the monitoring plan Version 01 of 15/09/2010. Addition to the Monitoring report version 05 of 27/11/2009 for period 01/01/2008-31/12/2008).

<sup>12</sup> Deviations are calculated as the difference between actual (monitoring report) and estimated (PDD) data. Deviations = (Actual data – Estimated data).

**Annex 1**

**GHGs project emissions calculation**

**Calculation of CO<sub>2</sub> emissions according to the project scenario for the period January - June 2011**

Parameter	Index in PDD	Data unit	January	February	March	April	May	June
Formula D.1								
Electricity consumption in OCP	$EC_{OCP,PI,y}$	MWh	39,993.3	37,661.0	40,456.1	40,162.7	40,729.4	38,886.2
CO <sub>2</sub> emission factor	$EF_{CO_2,ELEC,y}$	tCO <sub>2</sub> /MWh	1.090	1.090	1.090	1.090	1.090	1.090
Project emissions	$PE_{EC,y}$	tCO <sub>2</sub>	43,593	41,051	44,097	43,777	44,395	42,386

## Annex 2

### GHGs baseline emissions calculation

#### Calculation of baseline emissions for January - June of 2011

Parameter	Index in PDD	Data unit	January	February	March	April	May	June
Formula D.2.4								
Electricity consumption in OCP (Project scenario)	$EC_{OCP, PJ, y}$	MWh	39,993.3	37,661.0	40,456.1	40,162.7	40,729.4	38,886.2
Oxygen production in VRU-60	$P_{oxygen, VRU-60, y}$	thous. m <sup>3</sup> (O <sub>2</sub> )	38,384.4	34,595.7	39,146.8	41,454.6	39,776.2	37,718.6
Production of oxygen in reserved units	$P_{oxygen, RASU, y}$	thous. m <sup>3</sup> (O <sub>2</sub> )	-	-	-	-	-	-
Specific electricity consumption for oxygen production in OCP	$SEC_{oxygen, BL}$	MWh/thous. m <sup>3</sup> (O <sub>2</sub> )	1.042	1.089	1.033	0.969	1.024	1.031
Formula D.2.1								
Oxygen production (baseline)	$P_{oxygen, BL, y}$	thous. m <sup>3</sup> (O <sub>2</sub> )	44,640.0	40,320.0	44,640.0	43,392.0	44,640.0	43,200.0
Specific electricity consumption for oxygen production in OCP	$SEC_{oxygen, BL}$	MWh/thous. m <sup>3</sup> (O <sub>2</sub> )	1.042	1.089	1.033	0.969	1.024	1.031
Electricity consumption in OCP (baseline)	$EC_{OCP, BL, y}$	MWh	46,511.1	43,892.5	46,132.9	42,039.8	45,709.8	44,537.2
Formula D.2								
Electricity consumption (baseline)	$EC_{OCP, BL, y}$	MWh	46,511.1	43,892.5	46,132.9	42,039.8	45,709.8	44,537.2
CO <sub>2</sub> emission factor	$EF_{CO_2, ELEC, y}$	tCO <sub>2</sub> /MWh	1.090	1.090	1.090	1.090	1.090	1.090
Baseline emissions	$BE_{EC, y}$	tCO <sub>2</sub>	50,697	47,843	50,285	45,823	49,824	48,546